

ABSTERGE ACME FILTER



S
A
V
E
A
I
R

ORIFICE DIA MM	AIR LEAKAGE CFM	POWER WASTED KW	POWER WASTED IN YRS IN RS.
<u>3KG/CM2</u>			
0.4	0.211	0.036	.1148
0.8	0.845	0.144	4.597
1.6	3.38	0.575	18,387
3.2	13.5	2.3	73,440
6.25	54.1	9.2	29,4304
<u>4KG/CM2</u>			
0.4	0.264	0.045	1,436
0.8	1.06	0.180	5,766
1.6	4.23	0.719	23,011
3.2	16.9	2.87	9,1936
6.25	64.6	10.98	3,51,424
<u>5.5KG/CM2</u>			
0.4	0.335	0.057	1,822
0.8	1.34	0.228	7,290
1.6	5.36	0.911	29,158
3.2	21.4	3.64	1,16,416
6.25	85.7	14.57	4,66,208

S
A
V
E
M
O
N
E
Y

ABSTERGE ACME FILTER INDIA PVT LTD

9 SARANG SOCIETY GARKHEDA ROAD OPP SWAGAT HALL AURANGABAD 3
o/t/ telefax : 0240 – 2451033 , 2452243 , email : sushil@a2f-filters.com